



## **The storage and handling of flammable and combustible liquids**

**STANDARDS**  
Australia



This Australian Standard® was prepared by Committee ME-017, Flammable and Combustible Liquids. It was approved on behalf of the Council of Standards Australia on 13 July 2017.

This Standard was published on 1 August 2017.

---

The following are represented on Committee ME-017:

- Australasian Fire and Emergency Service Authorities Council
- Australasian Institute of Dangerous Goods Consultants
- Australian Industry Group
- Australian Institute of Petroleum
- Australian Paint Manufacturers Federation
- Department of Defence
- Department of Justice, Tas.
- Department of Mines and Petroleum, WA
- Engineers Australia
- Fire Protection Association Australia
- Insurance Council of Australia
- Plastic and Chemicals Industries Association
- SafeWork SA
- WorkCover NSW
- Workplace Health and Safety, Qld
- WorkSafe, Vic.

Additional Interests:

- Accord Australasia
  - AusSpill Association
  - WorkCover Queensland
- 

This Standard was issued in draft form for comment as DR AS 1940:2017.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

---

### **Keeping Standards up-to-date**

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting [www.standards.org.au](http://www.standards.org.au)

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

Australian Standard<sup>®</sup>

**The storage and handling of flammable  
and combustible liquids**

Originated as part of AS CB5—1942.  
Previous edition AS 1940—2004.  
Sixth edition AS 1940:2017.

**COPYRIGHT**

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

ISBN 978 1 76035 857 0

## PREFACE

This Standard was prepared by Standards Australia Committee ME-017, Flammable and Combustible Liquids, to supersede AS 1940—2004. The objective of this Standard is to promote the safety of persons and prevent damage to property and the environment where flammable or combustible liquids are stored or handled.

The changes in this revision of the Standard include alignment for the classification criteria of C1 combustible liquids to the Globally Harmonized System of Classification and Labelling of Chemicals (GHS). The use of plastic polyethylene or other composite polymeric tanks for the minor storage of combustible liquids is now permitted. Some changes to fire hydrants requirements were also made in Section 11, dealing with fire protection for package stores.

Committee ME-017 reviewed the report with recommendations into the Buncefield oil depot fire in Hertfordshire UK in 2005, and implemented engineering controls accordingly, wherever possible.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendices to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard. Notes that appear in the main text of this Standard provide information only.

The series of Standards covering the storage and handling of Class 3 and related dangerous goods presently comprises the following Standards:

AS	
1894	The storage and handling of non-flammable cryogenic and refrigerated liquids
2106	Methods for the determination of the flash point of flammable liquids (closed cup) (series)
2507	The storage and handling of agricultural and veterinary chemicals
2585	Determination of flash and fire points—Cleveland open cup method
2714	The storage and handling of organic peroxides
3780	The storage and handling of corrosive substances
3846	The handling and transport of dangerous cargoes in port areas
3961	The storage and handling of liquefied natural gas
4326	The storage and handling of oxidizing agents
4332	The storage and handling of gases in cylinders
4897	The design, installation and operation of underground petroleum storage systems
4976	The removal and disposal of underground petroleum storage tanks
AS/NZS	
1596	The storage and handling of LP Gas
2022	Anhydrous ammonia—Storage and handling
2927	The storage and handling of liquefied chlorine gas
3833	The storage and handling of mixed classes of dangerous goods, in packages and intermediate bulk containers

## AS/NZS

- 4081 The storage, handling and transport of liquid and liquefied polyfunctional isocyanates
- 4452 The storage and handling of toxic substances
- 4681 The storage and handling of Class 9 (miscellaneous) dangerous goods and articles
- 5026 The storage and handling of Class 4 dangerous goods
- 60079 Explosive atmospheres
  - 60079.10.1 Part 10.1: Classification of areas—Explosive gas atmospheres
  - 60079.14 Part 14: Electrical installations design, selection and erection

## CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	8
1.2 APPLICATION .....	8
1.3 NORMATIVE REFERENCES .....	9
1.4 DEFINITIONS.....	9
SECTION 2 MINOR STORAGE	
2.1 SCOPE OF SECTION .....	20
2.2 MINOR STORAGE QUANTITIES .....	20
2.3 PRECAUTIONS APPLYING TO MINOR STORAGE.....	26
2.4 MINOR STORAGE IN TANKS .....	27
SECTION 3 GENERAL REQUIREMENTS	
3.1 SCOPE OF SECTION .....	28
3.2 GENERAL DESIGN AND CONSTRUCTION REQUIREMENTS .....	28
3.3 MECHANICAL EQUIPMENT AND INSTALLATIONS.....	30
3.4 ELECTRICAL INSTALLATIONS AND EQUIPMENT .....	30
3.5 INTERNAL COMBUSTION ENGINES .....	30
3.6 LIGHTING .....	31
3.7 RESTRICTED USAGE .....	31
3.8 FIREWALLS AND VAPOUR BARRIERS.....	31
3.9 SECURITY, SIGNS AND NOTICES.....	32
3.10 TRANSIT STORAGE .....	32
3.11 IGNITION SOURCES.....	34
SECTION 4 PACKAGE STORAGE AND HANDLING AREAS	
4.1 SCOPE OF SECTION .....	35
4.2 TYPES OF STORES .....	35
4.3 LOCATION AND SEPARATION DISTANCES .....	39
4.4 CONSTRUCTION.....	43
4.5 VENTILATION.....	45
4.6 GENERAL REQUIREMENTS.....	51
4.7 STORAGE OF IBCs.....	51
4.8 STORAGE IN FREIGHT CONTAINERS.....	51
4.9 STORAGE IN STORAGE CABINETS .....	52
4.10 ACTIVITIES WITHIN PACKAGE STORES .....	54
4.11 OFFICES WITHIN PACKAGE STORES .....	54
SECTION 5 STORAGE IN TANKS	
5.1 SCOPE OF SECTION .....	55
5.2 GENERAL REQUIREMENTS.....	56
5.3 STORAGE TANK FILL POINTS .....	58
5.4 VENTING .....	59
5.5 EMERGENCY VENTING .....	63
5.6 LOCATION AND CAPACITY OF INDOOR TANKS .....	64
5.7 SEPARATION OF ABOVE-GROUND TANKS.....	65
5.8 BUNDS AND COMPOUNDS.....	68
5.9 REQUIREMENTS FOR ABOVE-GROUND TANKS WITH INTEGRAL SECONDARY CONTAINMENT.....	71

	<i>Page</i>
5.10 REQUIREMENTS FOR TANK CONTAINERS (ISO TANKS, PORTABLE TANKS) INCLUDING IBCs WHEN USED AS STATIC STORAGE TANKS .....	73
5.11 INSTALLATION METHODS FOR ABOVE-GROUND TANKS .....	73
5.12 INSTALLATION METHODS FOR UNDERGROUND TANKS .....	74
5.13 INSTALLATION METHODS FOR TANKS IN TANK CHAMBERS .....	75
5.14 SERVICE TANKS.....	76
 SECTION 6 SYSTEMS FOR PIPING, VALVES, PUMPS AND TANK HEATING	
6.1 GENERAL DESIGN AND CONSTRUCTION .....	78
6.2 PIPING .....	78
6.3 VALVES .....	80
6.4 PUMPS.....	81
6.5 HEATING OF LIQUIDS .....	81
 SECTION 7 FUEL DISPENSING	
7.1 SCOPE OF SECTION .....	83
7.2 GENERAL REQUIREMENTS.....	83
7.3 DISPENSERS.....	84
7.4 DELIVERY HOSES AND NOZZLES .....	86
7.5 MARINE DISPENSERS.....	86
7.6 OPERATIONS.....	87
 SECTION 8 TANK VEHICLE LOADING FACILITIES	
8.1 SCOPE OF SECTION .....	89
8.2 GENERAL REQUIREMENTS.....	89
8.3 TOP-FILLING INSTALLATIONS.....	91
8.4 BOTTOM-LOADING FACILITIES.....	92
 SECTION 9 OPERATIONAL AND PERSONNEL SAFETY	
9.1 SCOPE OF SECTION .....	94
9.2 GENERAL PRECAUTIONS.....	94
9.3 OPERATING PROCEDURES.....	97
9.4 MANAGEMENT OF ABOVE-GROUND LEAKS AND SPILLS .....	98
9.5 PLACARDING.....	100
9.6 LIQUID TRANSFER.....	100
9.7 EFFLUENT CONTROL .....	100
9.8 CONSTRUCTION AND MAINTENANCE WORK .....	100
9.9 GAS-FREEING OF TANKS AND PACKAGES.....	103
9.10 PERSONNEL TRAINING.....	103
9.11 RECORDS.....	104
9.12 PERSONAL PROTECTIVE EQUIPMENT (PPE) .....	105
9.13 FIRST AID .....	105
9.14 ADDITIONAL REQUIREMENTS FOR THE STORAGE AND HANDLING OF PACKAGES .....	106
9.15 ADDITIONAL REQUIREMENTS FOR PIPING AND VALVE SYSTEMS.....	108
9.16 ADDITIONAL REQUIREMENTS FOR PIPEWORK .....	108
9.17 ADDITIONAL REQUIREMENTS FOR TANKS .....	108
9.18 BULK TRANSFER .....	113

SECTION 10 EMERGENCY MANAGEMENT	
10.1 SCOPE OF SECTION .....	116
10.2 PLANNING FOR EMERGENCIES .....	116
10.3 MANIFEST .....	117
10.4 PLACARDING.....	117
SECTION 11 FIRE PROTECTION	
11.1 SCOPE OF SECTION .....	118
11.2 APPLICATION OF SECTION .....	118
11.3 GENERAL REQUIREMENTS FOR FIRE PROTECTION EQUIPMENT .....	118
11.4 PORTABLE FIRE EXTINGUISHERS.....	120
11.5 FIXED FIRE PROTECTION AND DETECTION SYSTEMS .....	121
11.6 FIRE EXTINGUISHER REQUIREMENTS FOR PRODUCT PUMPS, MANIFOLDS AND HOSE CONNECTION POINTS .....	123
11.7 FIRE EXTINGUISHER REQUIREMENTS FOR TANK VEHICLE TRANSFER AREAS .....	123
11.8 FIRE PROTECTION REQUIREMENTS FOR PACKAGE STORAGE AND HANDLING AREAS .....	124
11.9 FIRE PROTECTION REQUIREMENTS FOR FUEL DISPENSING INSTALLATIONS .....	127
11.10 FIRE PROTECTION REQUIREMENTS FOR ABOVE-GROUND FIRE-RATED TANKS, TANKS UNDERGROUND OR IN CHAMBERS.....	127
11.11 FIRE PROTECTION REQUIREMENTS FOR ABOVE-GROUND TANK STORAGE OF AGGREGATE CAPACITY LESS THAN 60 m <sup>3</sup> .....	127
11.12 FIRE PROTECTION REQUIREMENTS FOR ABOVE-GROUND TANK STORAGE OF AGGREGATE CAPACITY 60 m <sup>3</sup> TO 2000 m <sup>3</sup> .....	129
11.13 FIRE PROTECTION REQUIREMENTS FOR ABOVE-GROUND TANK STORAGE OF AGGREGATE CAPACITY 2000 m <sup>3</sup> AND GREATER.....	130
11.14 PIPING AND PUMPING SYSTEMS .....	132
11.15 COOLING WATER.....	133
11.16 FIXED FOAM SYSTEMS FOR TANKS .....	134
SECTION 12 WASTE STORAGE AND DISPOSAL	
12.1 SCOPE OF SECTION .....	139
12.2 STORAGE OF WASTES .....	139
12.3 WASTE MANAGEMENT .....	139
12.4 WASTE DISPOSAL .....	139
12.5 PRE-DISPOSAL TREATMENT OF EMPTY CONTAINERS.....	139
12.6 METHODS OF DISPOSAL.....	140
APPENDICES	
A LIST OF REFERENCED DOCUMENTS.....	141
B RECOMMENDATIONS FOR THE DESIGN AND CONSTRUCTION OF BLENDING PLANTS .....	145
C USE OF FORK-LIFT TRUCKS AND VEHICLES NOT RATED FOR HAZARDOUS AREAS IN FLAMMABLE LIQUIDS PACKAGE STORES .....	148
D RECOMMENDATIONS FOR THE STORAGE AND HANDLING OF PACKAGED FLAMMABLE LIQUIDS IN COOLROOMS.....	152
E ISSUES TO BE CONSIDERED IN A RISK ASSESSMENT.....	154
F STORAGE AND HANDLING OF POTABLE SPIRITS IN BULK .....	157
G POWER STATION AND GRID TRANSFORMERS .....	161
H TANK VENTING.....	162
I FIRE EXPOSURE PROTECTION .....	166



	<i>Page</i>
J COMBUSTION CHARACTERISTICS.....	170
K GAS-FREEING PRECAUTIONS AND PRINCIPLES .....	172
L RECOMMENDATIONS FOR BATCH BLENDING OF FLAMMABLE LIQUIDS .....	174
BIBLIOGRAPHY.....	177

## STANDARDS AUSTRALIA

**Australian Standard****The storage and handling of flammable and combustible liquids**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard sets out requirements and recommendations for the safe storage and handling of flammable liquids of dangerous goods Class 3, as classified in the UN *Recommendations for the Transport of Dangerous Goods—Model Regulations* and listed in the ADG Code. This Standard also provides requirements and recommendations for the storage and handling of combustible liquids, as defined in Clause 1.4.9.

This Standard provides minimum acceptable safety requirements for storage facilities, operating procedures, emergency planning and fire protection. It provides technical guidance that may assist in the storage and handling of flammable and combustible liquids in accordance with the risk management requirements of Safe Work Australia, Model Code of Practice, *Managing Risks of Hazardous Chemicals in the Workplace* and legislation which underpins that document.

This Standard provides requirements for commonly used flammable and combustible liquids such as hydrocarbons and industrial solvents. Some flammable and combustible liquids have other physical and chemical properties that require additional precautions and design considerations. Examples of these are—

- (a) liquids that can polymerize;
- (b) liquids that require blanketing with inert gas;
- (c) liquids that are heated; and
- (d) liquids that are assigned a subsidiary risk.

Any special precautions and considerations necessary for the safe storage and handling of such liquids are additional to the requirements and recommendations provided in this Standard.

For the storage and handling of dangerous goods of another class but having a Class 3 subsidiary risk, this Standard is relevant to their flammability aspects.

NOTE: Fuel blends that contain biofuel (e.g. ethanol) have physical and chemical properties that require additional precautions and design considerations.

**1.2 APPLICATION****1.2.1 Where this Standard applies**

This Standard applies to the storage and handling of Class 3 dangerous goods as defined in Clause 1.4.8 or relevant legislation, with the exception of desensitized explosives of Class 3. It also applies to the storage and handling of combustible liquids. The requirements of this Standard apply in conjunction with, but do not take precedence over, any government legislation that applies in any area.

Where the flammable liquid being kept has one or more subsidiary risks, reference shall be made to the Australian Standards relevant to the Classes of those risks and the more stringent requirements shall apply. Where any combustible liquid being kept has risks of other Classes, the relevant Australian Standard for that Class shall be consulted, but for requirements relating to its combustible properties and fire safety, this Standard shall apply.