



## **Substations and high voltage installations exceeding 1 kV a.c.**



This Australian Standard® was prepared by Committee EL-043, High Voltage Installations. It was approved on behalf of the Council of Standards Australia on 4 August 2016. This Standard was published on 14 September 2016.

---

The following are represented on Committee EL-043:

- Australian Chamber of Commerce and Industry
  - Australian Industry Group
  - Bureau of Steel Manufacturers of Australia
  - CIGRE
  - Communications, Electrical and Plumbing Union—Electrical Division
  - Consult Australia
  - Department of Industry, Skills and Regional Development, NSW
  - Department of Mines and Petroleum, WA
  - Electrical Regulatory Authorities Council
  - Energy Networks Association
  - Engineers Australia
  - Institute of Electrical Inspectors
- 

This Standard was issued in draft form for comment as DR AS 2067:2014.

Standards Australia wishes to acknowledge the participation of the expert individuals that contributed to the development of this Standard through their representation on the Committee and through the public comment period.

---

### **Keeping Standards up-to-date**

Australian Standards® are living documents that reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued.

Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments that may have been published since the Standard was published.

Detailed information about Australian Standards, drafts, amendments and new projects can be found by visiting [www.standards.org.au](http://www.standards.org.au)

Standards Australia welcomes suggestions for improvements, and encourages readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.org.au](mailto:mail@standards.org.au), or write to Standards Australia, GPO Box 476, Sydney, NSW 2001.

---

Australian Standard<sup>®</sup>

**Substations and high voltage  
installations exceeding 1 kV a.c.**

Originated as AS 2067—1977.  
Previous edition 2008.  
Third edition AS 2067:2016.

**COPYRIGHT**

© Standards Australia Limited

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968.

ISBN 978 1 76035 559 3

## PREFACE

This Standard was prepared by the Standards Australia Committee EL-043, High Voltage Installations, to supersede AS 2067—2008, *Substations and high voltage installations exceeding 1 kV a.c.*

The objective of this Standard is to provide common rules for the design and the erection of electrical power installations in systems with nominal voltages above 1 kV a.c. and nominal frequency up to and including 60 Hz.

The objective of this revision is to incorporate changes derived from experience and feedback following the issue of the 2008 edition of this Standard, amendments that have been made to IEC 61936, and to incorporate review of consideration of fire issues, requirements related to the mining area for fixed installations, as considered by EL-023, Electrical Equipment in Mines and Quarries, and substantially expand the sections and clauses on earthing, following reference to ENA's Handbook ENA Doc 025, EG-0 on earthing.

This Standard is based on but not equivalent to IEC 61936-1:2010, *Power installations exceeding 1 kV a.c.*, Part 1: *Common rules*, and its Amendment 1 (2014).

Where a reference is made to 'national regulations', it is intended to encompass national, state or territory and local regulations.

The terms 'normative' and 'informative' are used to define the application of the appendix to which they apply. A normative appendix is an integral part of a standard, whereas an informative appendix is only for information and guidance.

Statements expressed in mandatory terms in notes to figures and tables are deemed to be requirements of this Standard.

## CONTENTS

	<i>Page</i>
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE.....	5
1.2 APPLICATION .....	6
1.3 NORMATIVE REFERENCES .....	6
1.4 DEFINITIONS.....	8
<b>SECTION 2 FUNDAMENTAL REQUIREMENTS</b>	
2.1 GENERAL.....	18
2.2 ELECTRICAL REQUIREMENTS .....	19
2.3 CIVIL AND STRUCTURAL REQUIREMENTS.....	21
2.4 CLIMATIC AND ENVIRONMENTAL CONDITIONS .....	27
2.5 SPECIAL REQUIREMENTS .....	30
2.6 SITE SELECTION .....	31
2.7 RISK MANAGEMENT .....	31
<b>SECTION 3 INSULATION</b>	
3.1 GENERAL.....	33
3.2 SELECTION OF INSULATION LEVEL .....	33
3.3 VERIFICATION OF WITHSTAND VALUES .....	33
3.4 MINIMUM CLEARANCES OF LIVE PARTS .....	34
3.5 MINIMUM CLEARANCES BETWEEN PARTS UNDER SPECIAL CONDITIONS .....	39
3.6 TYPE TESTED EQUIPMENT .....	40
<b>SECTION 4 EQUIPMENT</b>	
4.1 GENERAL REQUIREMENTS.....	41
4.2 SPECIFIC REQUIREMENTS .....	42
<b>SECTION 5 INSTALLATIONS</b>	
5.1 MINIMUM REQUIREMENTS .....	52
5.2 OUTDOOR INSTALLATIONS OF OPEN DESIGN .....	57
5.3 INDOOR INSTALLATIONS OF OPEN DESIGN .....	64
5.4 INSTALLATION OF PREFABRICATED TYPE-TESTED SWITCHGEAR .....	65
5.5 REQUIREMENTS FOR BUILDINGS .....	66
5.6 HIGH VOLTAGE/LOW VOLTAGE PREFABRICATED SUBSTATIONS .....	71
5.7 ELECTRICAL INSTALLATIONS ON A MAST, POLE OR TOWER.....	71
<b>SECTION 6 SAFETY MEASURES</b>	
6.1 GENERAL.....	72
6.2 PROTECTION AGAINST DIRECT CONTACT .....	72
6.3 MEANS TO PROTECT PERSONS FROM INDIRECT CONTACT .....	74
6.4 MEANS TO PROTECT PERSONS WORKING ON OR NEAR ELECTRICAL INSTALLATIONS .....	74
6.5 PROTECTION FROM DANGER RESULTING FROM ARC FAULT.....	77
6.6 PROTECTION AGAINST DIRECT LIGHTNING STRIKES.....	77
6.7 PROTECTION AGAINST FIRE AND EXPLOSION .....	78
6.8 PROTECTION AGAINST LEAKAGE OF INSULATING LIQUIDS AND SF <sub>6</sub> .....	91
6.9 IDENTIFICATION AND MARKING.....	96
6.10 PROTECTION AGAINST UNAUTHORIZED ACCESS .....	97

SECTION 7 PROTECTION, CONTROL AND AUXILIARY SYSTEMS	
7.1	PROTECTION SYSTEMS ..... 98
7.2	MONITORING AND CONTROL SYSTEMS..... 99
7.3	A.C. AND D.C. SUPPLY CIRCUITS..... 100
7.4	COMPRESSED AIR SYSTEMS ..... 101
7.5	SF <sub>6</sub> GAS HANDLING PLANT ..... 102
7.6	BASIC RULES FOR ELECTROMAGNETIC COMPATIBILITY OF CONTROL SYSTEMS ..... 102
SECTION 8 EARTHING SYSTEMS	
8.1	GENERAL..... 105
8.2	FUNDAMENTAL REQUIREMENTS ..... 105
8.3	RISK MANAGEMENT AND DUE DILIGENCE ..... 106
8.4	DESIGN ..... 107
8.5	CONSTRUCTION..... 121
8.6	COMMISSIONING AND ONGOING MONITORING..... 122
8.7	MAINTENANCE, MODIFICATION AND REFURBISHMENT ..... 123
8.8	TESTING..... 124
8.9	DOCUMENTATION..... 124
SECTION 9 INSPECTION AND TESTING	
9.1	INSPECTIONS AND TESTS ..... 126
9.2	DOCUMENTATION AND RECORDS ..... 127
9.3	VERIFICATION OF SPECIFIED PERFORMANCES..... 127
9.4	TESTS DURING INSTALLATION AND COMMISSIONING ..... 127
9.5	TRIAL RUN ..... 127
SECTION 10 OPERATION AND MAINTENANCE MANUAL ..... 128	
APPENDICES	
A	VOLTAGE LIMITS AND RISK LEVEL ..... 129
B	SUBSTATION EARTHING SYSTEM..... 134
C	FIRE RISK ZONES FOR DISTRIBUTION SUBSTATIONS ..... 145
D	EMF AND SAFETY ISSUES—OBLIGATIONS RELATED TO THE DESIGN OF THE INSTALLATION ..... 154
E	TYPICAL SYSTEM FOR FUNCTIONAL IDENTIFICATION OF SMALL WIRING ..... 155
F	POWER SYSTEM PROTECTION..... 158
G	EARTHING VOLTAGE LIMIT CASE STUDIES ..... 175
H	EARTH SYSTEM TESTING ..... 204
BIBLIOGRAPHY ..... 220	

# STANDARDS AUSTRALIA

## Australian Standard

### Substations and high voltage installations exceeding 1 kV a.c.

#### SECTION 1 SCOPE AND GENERAL

##### 1.1 SCOPE

This Standard provides minimum requirements for the design and erection of high voltage installations in systems with nominal voltages above 1 kV a.c. and nominal frequency up to and including 60 Hz, so as to provide safety and proper functioning for the use intended.

For the purposes of this Standard, a high voltage installation is considered to be:

- (a) An electricity network substation, under the control of an electricity network operator or entity authorized by a licence or other legal instrument to convey electricity.
- (b) The high voltage parts of an electrical installation of a power station including all auxiliary systems and interconnecting lines and cables between power stations if on the same site.
- (c) Electrical installations built at offshore platforms, e.g. offshore wind power farms.
- (d) The high voltage parts of an electrical installation that are not covered in (a) or (b) above. This may include but not be limited to consumer and customer electrical installations serving premises such as factories, commercial facilities, industrial plants, institutional facilities and mine sites.

A high voltage installation includes, but is not limited to, the following equipment:

- (i) High voltage electrical installations on masts, poles and towers.
- (ii) Switchgear and/or transformers and/or electrical equipment located outside a closed electrical operating area.
- (iii) Rotating electrical machines.
- (iv) Switchgear, controlgear and assemblies.
- (v) Transformers and reactors.
- (vi) Converters.
- (vii) Cables.
- (viii) Lines.
- (ix) Wiring systems.
- (x) Batteries, battery chargers and associated d.c. supply systems.
- (xi) Capacitors.
- (xii) Earthing systems.
- (xiii) Buildings and fences that are part of a closed electrical operating area.
- (xiv) Associated protection, control, auxiliary and ancillary systems.
- (xv) Structures, foundations, earthworks and drainage.

NOTE: In general, a product Standard for an item of equipment takes precedence over this Standard.