



Australian/New Zealand Standard™

Plumbing and drainage

Part 2: Sanitary plumbing and drainage



AS/NZS 3500.2:2021

This joint Australian/New Zealand Standard[™] was prepared by joint Technical Committee WS-014, Plumbing and Drainage. It was approved on behalf of the Council of Standards Australia on 14 May 2021 and by the New Zealand Standards Approval Board on 7 April 2021.

This Standard was published on 28 May 2021.

The following are represented on Committee WS-014:

Association of Hydraulic Services Consultants Australia

Australian Building Codes Board

Australian Industry Group

Australian Stainless Steel Development Association

Backflow Prevention Association of Australia

Engineers Australia

Hydraulic Consultants Association Australasia

International Copper Association Australia

Master Plumbers Australia and New Zealand

Master Plumbers, Gasfitters and Drainlayers New Zealand

Ministry of Business, Innovation and Employment (NZ)

Plastics Industry Pipe Association of Australia

Plastics New Zealand

Plumbers, Gasfitters and Drainlayers Board (NZ)

Plumbing Distributors Association of New Zealand

Plumbing Products Industry Group

The Institute of Plumbing Australia

Water New Zealand

Water Services Association of Australia

This Standard was issued in draft form for comment as DR AS/NZS 3500.2:2021.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

Australian/New Zealand Standard™

Plumbing and drainage

Part 2: Sanitary plumbing and drainage

First published as AS 3500.2—1990. Jointly revised and redesignated as AS/NZS 3500.2.2:1996. Jointly revised and redesignated as AS/NZS 3500.2:2003. Second edition 2018. Third edition 2021.

@ Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2021

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand).

Preface

This Standard was prepared by the joint Standards Australia/Standards New Zealand Committee WS-014, Plumbing and Drainage, to supersede AS/NZS 3500.2:2018.

The objective of this document is to provide installers with deemed to satisfy solutions for compliance with —

- (a) the National Construction Code (NCC) Volume Three, Plumbing Code of Australia (PCA); and
- (b) the New Zealand Building Code (NZBC), Clause G13 Foul Water.

A list of all parts in the AS/NZS 3500 series for plumbing and drainage can be found in the Standards Australia and Standards New Zealand online catalogues.

The major changes in this revision are as follows:

- (i) Conformance to individual product standards has been removed. All products used in plumbing and drainage systems in Australia need to comply with the PCA and, in New Zealand, the NZBC, see Appendix A for further information. Removal of specific product standard conformance requirements avoids inconsistencies and contradictions between this document and the PCA and NZBC.
- (ii) Definitions have been relocated to AS/NZS 3500.0 for consistency across the series.
- (iii) The range of materials that can be used for wet wells has been expanded to encompass prefabricated wells.
- (iv) Changes to the requirements for the marking of pipes in commercial buildings to assist in the better identification of pipework and avoid cross connections.
- (v) Changes to the connection requirements for drains at grade.
- (vi) The requirement for a commercial dishwashing machine drainage just to connect to a disconnector gully with a 10 m discharge pipe has been removed. This allows the more effective arrangement of commercial kitchens.
- (vii) An appendix has been added providing guidance on the requirements of AS 2870 for flexible connections to be installed in plastics pipe drainage systems. It covers flexible connections, lagging and water ingress under the slab to accommodate a range of differential soil movement for Soil Classes M, M-D, H1, H1-D, H2, H2-D, E and E-D.
- (viii) Changes to the number of pressure attenuators required to allow more flexible installation options.

The terms "normative" and "informative" are used in Standards to define the application of the appendices to which they apply. A "normative" appendix is an integral part of a Standard, whereas an "informative" appendix is only for information and guidance.

Notes or footnotes to tables or figures that are expressed in mandatory terms are deemed to be requirements of this document.

Notes to clauses in this document are informative only and do not include requirements.

This document includes commentary on some of the clauses. The commentary directly follows the relevant clause, is designated by "C" preceding the clause number and is printed in italics in a box. The commentary is for information and guidance and does not form part of the document.

Standards Australia thanks the Moreton Bay Regional Council for permission to reproduce $\underline{\text{Figures G.5(A)}}$ and $\underline{\text{G.5(B)}}$. These figures are copyright of Moreton Bay Regional Council. All rights reserved.

Contents

Preface		i
Section 1	Scope and general	1
1.1	Scope	
1.2	Application	
	1.2.1 Australia	
	1.2.2 New Zealand	
1.3	Normative references	
1.4	Terms and definitions	2
1.5	Plastics abbreviations	
1.6	Measurement of pipe length	
1.7	Pipe grades	
1.8	Equivalent pipe sizes	
Section 2	Materials and products	
2.1	Scope of section	
2.2	General	
2.3	Pipes and fittings — General limitations	2
2.4	Metallic pipes and fittings	
	2.4.1 Sanitary plumbing and drainage systems	
	2.4.2 Limitations	
	2.4.3 Fabricated metallic pipes and fittings	
2.5	Plastics pipes and fittings	
	2.5.1 Sanitary plumbing and drainage systems	
	2.5.2 Limitations	
2.6	Pipes and fittings — Other materials	
	2.6.1 Sanitary plumbing and drainage systems	
	2.6.2 Limitations	
2.7	2.6.3 Pipes and fittings for pressure applications	
2.7	Sheet materials	
	2.7.1 Copper	
2.8	2.7.2 Stainless steel	
2.0	Joints	
	2.8.1 Flanged joints	
	2.8.3 Silver brazing alloy	
	2.8.4 Filler rods for stainless steel joints	
	2.8.5 Solvent cement and priming fluid	
2.9	Miscellaneous	
2.7	2.9.1 Concrete mix	
	2.9.2 Cement mortar	
	2.9.3 Water for concrete and mortar	
	2.9.4 Timber	
	2.9.5 Epoxy resins	
	2.9.6 Pipe bedding	
	2.9.7 Backfill	
	2.9.8 External protective coatings	
	2.9.9 Fibreglass-reinforced plastics tanks	10
Section 3	Drainage design	11
3.1	Scope of section	1
3.2	Location of drains	
3.3	Size and length of drains	
	3.3.1 Fixture unit loading	
	3.3.2 Main drain	
	3.3.3 Branch drains	
	3.3.4 Limitations on vented DN 80 branch drains	12

	3.3.5	Use of eccentric taper fitting	12
	3.3.6	Size change	12
	3.3.7	Downstream of boundary trap	12
	3.3.8	Oversizing of drains	12
	3.3.9	Maximum length of fixture discharge pipes	13
3.4	Grades of	of drains	13
	3.4.1	Minimum grade	13
	3.4.2	Reduced grades	13
	3.4.3	Steep grades	14
	3.4.4	Anchor blocks	14
3.5	Laying o	of drains	14
	3.5.1	General	14
	3.5.2	Easements and watercourses	15
3.6	Proximi	ty to other services	15
	3.6.1	General	15
	3.6.2	Above-ground services	
	3.6.3	Separation from underground electrical supply cables or consumer gas pipes.	15
	3.6.4	Separation from underground electrical earthing electrode	
	3.6.5	Separation from underground communication cable	16
	3.6.6	Separation from other underground services	
	3.6.7	Crossover of underground services	17
	3.6.8	Clearance from underground obstructions	
3.7	Depth o	f cover for buried pipes	
	3.7.1	General	
	3.7.2	Depth of cover	
	3.7.3	Drains installed with less than minimum cover	
	3.7.4	Drains under buildings	
3.8		gover drains	
	3.8.1	Alterations and additions to buildings	18
	3.8.2	Installation near and under buildings	18
	3.8.3	Fixture connections to vitrified clay drains under buildings	
3.9	Venting	of drains	
	3.9.1		
	3.9.2	Location	
	3.9.3	Size of drainage vents	
3.10		ed branch drains	
		General	
	3.10.2	· · · · · · · · · · · · · · · · · · ·	
		Maximum length	
		Vertical sections	
		Connection of fixture discharge pipes	
3.11		ted drains discharging to gullies	
		General	
	3.11.2		
3.12		pe to disconnector gully	
3.13		tion on connections in proximity to a stack	
3.14		ction of basement fixtures	
3.15		ctions in flood-prone areas	
		Inlet above flood level	
041		Inlet below flood level	
3.16		of existing sanitary drains	
		Re-use where buildings are demolished or removed	
		Re-use in existing buildings	
2 4 7		Renovation techniques	
3.17	-	points	
	3.17.1	1 1	
2 10		Connection points for short-term sites	
3.18	שrains	connected to network utility operator vacuum sewerage systems	3U

Section 5	Excavation bedding support and backfilling	63 63
Cooking F	4.11.2 Sealing	
	4.11.1 Disconnection from the sewer	
4.11	6	
4.10	Jump-ups	
	4.9.4 Junctions for stacks connected to below-ground drainage	
	4.9.3 Square junctions	
	4.9.2 Junctions installed in vertical plane	
	4.9.1 Drains installed at grade	
4.9	Junctions in drains	
	4.8.4 Differential settlement	
	4.8.3 Construction	
	4.8.2 Size	
	4.8.1 General	
4.8	Inspection chambers	55
	4.7.5 Sealing	55
	4.7.4 Access to inspection openings	55
	4.7.3 Types	54
	4.7.2 Size	
	4.7.1 Location	53
4.7	Inspection openings	53
	4.6.8 Charging floor waste gullies	
	4.6.7 Floor waste gullies	
	4.6.6 Overflow relief gullies	
	4.6.5 Disconnector gullies inside buildings	
	4.6.4 Soil fixtures	
	4.6.3 Maintenance of water seal	
	4.6.2 Installation	
110	4.6.1 General	
4.6	Gullies	
	4.5.4 Reflux valve chambers	
	4.5.3 Surcharging sewer	
	4.5.2 Installation	
1.5	4.5.1 Location	
4.5	Reflux valves	
	4.4.4 Installation of boundary traps	
	4.4.3 Installation of inspection shafts	
	4.4.2 Inspection shafts and boundary trap risers	
7.7	4.4.1 General	
4.4	Inspection shafts and boundary traps	32 32
	4.3.4 Maximum length of fixture discharge pipes	
	4.3.3 Changes of direction	
	4.3.2 Above ground under buildings	
7.5	4.3.1 Below ground	
4.3	Drains	
	4.2.2 Tidal or water-charged locations	
7.2	4.2.1 General	
	Point of connection	
4.1	Scope of section	
Section 4	Drainage system	27
3.20	O .	
	3.19.4 Sullage tanks	
	3.19.3 Septic tanks	
	3.19.2 Drainage connections	
0.17	3.19.1 General	
3.19	Common effluent drainage system	31

5.2	Excavation of trenches	
	5.2.1 Trench dimensions	63
	5.2.2 Over-excavation	63
	5.2.3 Water-charged ground	63
5.3	Concrete support for drains	
5.4	Bedding of drains	64
	5.4.1 General	64
	5.4.2 Bedding materials	64
	5.4.3 Pipe side support and overlay materials	64
	5.4.4 Bedding and backfill	64
	5.4.5 Minimum cover	
5.5	Installation of backfill materials	65
	5.5.1 General	65
	5.5.2 Excavated material	65
5.6	Drains in other than stable ground	65
Coation (S	
Section 6	General design requirements for sanitary plumbing systems	
6.1	Scope of section	
6.2	Renovation	
6.3	Fixture unit ratings	
6.4	Venting for fixtures discharge pipes	
6.5	Trapping of fixtures and appliances	
	6.5.1 General	
	6.5.2 Water seal	
	6.5.3 Location of traps and self-sealing devices	
	6.5.4 Multiple outlets	69
6.6	Graded discharge pipes	
	6.6.1 Minimum grades	
	6.6.2 Connection methods	
6.7	Junctions in stacks	
	6.7.1 Types	72
	6.7.2 Restrictions for square and ball junctions	
	6.7.3 Opposed connections	
6.8	Connections near base of stacks	
	6.8.1 Connections to drains or graded pipes	75
	6.8.2 Connections above base of stack	
	6.8.3 Connection of stacks to graded pipes or drains above ground	77
	6.8.4 Bends at the base of stacks	
6.9	Vents	
	6.9.1 General	
	6.9.2 Minimum grade	
	6.9.3 Interconnections	
	6.9.4 Termination	
	6.9.5 Connection to graded pipes	79
6.10	Air admittance valves	80
	6.10.1 General	80
	6.10.2 Requirements for use	80
	6.10.3 Location	82
	6.10.4 Installation	82
6.11	Pressure attenuators	84
	6.11.1 General	84
	6.11.2 Installation of pressure attenuators	84
	6.11.3 Location of pressure attenuators	
Section 7	•	
	Greywater plumbing and drainage systems	
7.1 7.2	Scope of section	
	Material and products	
7.3	Installation requirements	
/.4	HISTALIALIUH TEUUH EHIERUS	ന /

	B Fully vented systems and fully vented modified systems — Design and	00
	stallation	89
_	1 Scope of section	
8.	2 System types	
	8.2.1 General	
	8.2.2 Fully vented system 8.2.3 Fully vented modified system	
0	5	
8.	3 Size of discharge pipes	
	8.3.1 General	
	8.3.2 Fixture unit loading 8.3.3 Minimum size	
	8.3.4 Limitation on DN 80 pipes	
Q	4 Size of stacks	
	5 Venting	
0.	8.5.1 Trap vents	
	8.5.2 Branch vents	
	8.5.3 Relief vents	
	8.5.4 Stack vents	
	8.5.5 Cross-relief vents	
	8.5.6 Header vents	
	8.5.7 Group and common vents	
8.	1	
0.	8.6.1 Steep offsets	
	8.6.2 Graded offsets	
		100
Section 9	9 Single stack systems and single stack modified systems — Design and astallation	100
	1 Scope of section	
9.	=	
9.	9.2.1 General	
	9.2.2 Single stack system	
	9.2.3 Single stack modified system	
	9.2.4 Design requirements	
	9.2.5 Number of floor levels	
q	3 Rating of fixtures	
9.		
٦.	9.4.1 Domestic or residential buildings	
	9.4.2 Commercial or industrial buildings	
9.		
٥.	9.5.1 Separate fixture discharge pipes	
	9.5.2 Acceptable variations	
	9.5.3 Opposed junctions	
	9.5.4 Bends in fixture discharge pipes	
	9.5.5 Vertical dropper on fixture discharge pipes	
	9.5.6 Connection from waste fixtures to stack	
	9.5.7 Connection from waste fixtures to stack below restricted zone	
	9.5.8 Floor waste gullies	
	9.5.9 Traps	
	9.5.10 Connection of ranges of fixtures	
	9.5.11 Ranges of basins	
	9.5.12 Range of water closet pans	
	9.5.13 Range of wall-hung urinals	
9.		
,	9.6.1 General	
	9.6.2 Cross-vents (single stack modified system)	
	9.6.3 Relief vents (single stack modified system)	
9.		
	9.7.1 Single stack systems	

		9.7.2	Single stack modified systems	125
9.	.8 V		ns to single stack systems	
			General	
			DN 80 stack	126
		9.8.3	DN 80 stack with the top section graded and installed in a domestic or	
			residential building	127
		9.8.4	DN 100 stack up to three floors with the top section graded and installed in	
			a domestic or residential building receiving 30 fixture units	128
			DN 100 stack of one floor with top section graded	
			Connection of multiple fixtures into or below a graded offset (DN 100 stacks)130
		9.8.7	Waste stack up to DN 100 with either graded or steep offset between the	
			highest and lowest connections	
			DN 65 waste stack	
			DN 50 vertical section of stack	
0	0 0		Connection at the change of direction in stack with top section graded	
9.	.9 (n single stack systems only	
			General	
			Steep offsets	
			Connection of laundry troughs to DN 100 stacks	13/
		9.9.4	Steep offsets below the lowest connection	
		9.9.5	Graded offsets	
			Connections above the offset	
Section 1	10 (General	installation of pipework	140
			of section	
1	0.2		t and fixing of pipework	
			Brackets, clips and hangers	
			Limitation of pipe supports	
			Holes in framework	
			n	
10	0.4		lment of pipes and fittings	
		10.4.1	General	
		10.4.2	Extension of inspection openings	
		10.4.3	Structural concrete or brickwork	
		10.4.4	Drywall construction	
		10.4.5	Multiple dwellings	
1.	0 5	10.4.6	Walk-in pipe ducts	
10	0.5		and inspection openings	
		10.5.1	General Lagation of testing and inspection on pair as	
		10.5.2	Location of testing and inspection openings	
		10.5.3 10.5.4	Size of testing and inspection of openings	
1,	0.6		tion of copper and copper alloy pipes	
11	0.6	10.6.1	General	
		10.6.1	Fixing	
		10.6.2	Expansion joints	
		10.6.4	Freedom from restraint	
1.	0.7		tion of other metallic pipes and fittings	
			tion of plastics pipes and fittings	
1,	0.0	10.8.1	PVC-U pipe systems	
		10.8.2	ABS pipe systems	
		10.8.3	PE pipe systems	
		10.8.4	Installation of other plastics pipe systems	
10	0.9		nection of sanitary plumbing	
			fication of pipes	
	0.11		lation of above-ground pipework and connection of fixtures using drainage	2 10
			oles	146
			l General	
			2 Maximum length and size	

		10.11.3 Applicable installations	146
		10.11.4 Installation	146
	10.12	Installation of boundary traps, reflux valves and gullies above ground within	
		buildings	147
		10.12.1 Boundary traps	
		10.12.2 Reflux valves	
		10.12.3 Gullies	
	10 12		
	10.13	, 0 11	
		10.13.1 General	
		10.13.2 Bolted gland joints (BG)	
		10.13.3 Rubber ring joints (RR)	
		10.13.4 Epoxy resin joints (ER)	
		10.13.5 Cement mortar joints (CM)	
		10.13.6 Silver brazed joints (SB)	150
		10.13.7 Solvent cement joints (SC)	150
		10.13.8 Threaded joints (TH)	150
		10.13.9 Band-clamped sleeve joints (BC)	
		10.13.10 PE joints	
		·	
Section	n 11	Reduced velocity aerator stack system	
	11.1	Scope of section	
	11.2	General	151
	11.3	Size of stacks	151
	11.4	Stack vents	151
	11.5	Offsets in stacks	
		11.5.1 General	
		11.5.2 Pressure relief bypass for stack offsets	
	11.6	Aerator junction fittings	
	11.0	11.6.1 General	
	117	11.6.2 Opposed connections	
	11.7	Maximum length of discharge pipes	
	11.8	Size of discharge pipes	
	11.9	De-aerators	155
Section	112	Pumped discharge	157
	12.1	Scope of section	
	12.2	General	
	12.3		
		Compressed air ejection Ejector vent	157
	12.4		
	12.5	Wet wells	
		12.5.1 General	
		12.5.2 Construction	
		12.5.3 Base	
		12.5.4 Cover	158
		12.5.5 Ladders	158
	12.6	Installation of pumps	158
		12.6.1 General	158
		12.6.2 Inlet to wet well	
		12.6.3 Venting	
		12.6.4 Sealing	
	12.7	Pumped discharges or rising mains	
	12.7	Pump discharge from waste fixtures	
	14.0		
		12.8.1 General	
		12.8.2 Holding tank	
		12.8.3 Provision of valves	
		12.8.4 Inlet	
		12.8.5 Outlet size	
		12.8.6 Venting	
		12.8.7 Pump discharge pipe	159

	12.9	Small bore macerator pumps	160
Sectio	n 13	Fixtures and appliances	161
	13.1	Scope of section	
	13.2	Installation of sanitary fixtures for people with a disability	161
	13.3	General installation requirements	
		13.3.1 Installation of fixtures	
		13.3.2 Location of fixture traps or self-sealing devices	
		13.3.3 Untrapped fixtures	
		13.3.4 Connection of combination fixtures in pairs	
		13.3.5 Connection of soil fixtures	
		13.3.6 Fixture grates	
		13.3.7 Fixture discharge pipes	
	13.4	Plant rooms	
	13.5	Pressurized chambers	
	13.6	Autopsy tables	
	13.7	Bain-maries and boiling water units	
	13.7	Basins	
	13.9	Baths	
	13.10	Bedpan washers and sanitizers	
	13.11	Bidets	
	13.12	Dental units	
		13.12.1 Single	
		13.12.2 Multiple	
	13.13		
	13.14		163
	13.15		
		commercial coffee-making machines and ice-making machines	163
		13.15.1 General	163
		13.15.2 Shower groups	163
	13.16	Macerating sanitary napkin disposal units	163
	13.17	Showers	164
		13.17.1 Individual showers	164
		13.17.2 Common channels	
	13.18	Sinks	164
		13.18.1 Kitchen sinks	
		13.18.2 Bar sinks	
		13.18.3 Cleaners' sinks	
		13.18.4 Pot, utility and laboratory sinks	165
	13.19		
	13.17	13.19.1 Connection	
		13.19.2 Installation	
	13.20	Instrument sterilizers and autoclaves	
		Connection of tundishes	
	13.21		
	13.23		
		13.23.1 Ablution	
	1224	13.23.2 Laundry	
	13.24		
		13.24.1 Slab type	
		13.24.2 Wall-hung	
	40.05	13.24.3 Conversion to waterless urinals	
	13.25	0	
		13.25.1 Clothes-washing machines	
		13.25.2 Domestic dishwashing machines	
		13.25.3 Commercial dishwashing machines	
		13.25.4 Glass-washing machines	
	13.26	11	
		13.26.1 General	169

	13.26.2 Restrictions on use	169
	13.26.3 Installation	169
	13.26.4 Termination of discharge pipe	169
13.2	27 Water closet pans	
	13.27.1 Connection	
	13.27.2 Installation	
Section 14	Multi-unit developments	171
14.1		
14.2	<u>•</u>	
14.2	14.2.1 General	
	14.2.2 Maintenance shafts	
	14.2.3 Inspection shafts and overflow relief gullies and open upstream vents at	1/1
	each individual residential building	171
C .: 45		
	Testing of sanitary plumbing and sanitary drainage installations	
15.1		
15.2	J	
15.3	1	
	15.3.1 Sealing inlets and outlets	
	15.3.2 Air pressure test procedure	
	15.3.3 Maximum pressure drop	
15.4		
	15.4.1 Sealing inlets and outlets	
	15.4.2 Vacuum test procedure	
	15.4.3 Maximum vacuum drop	174
Section 16	Vacuum drainage design and installation	175
16.3	- · · F · · · · · · · · · · · · · · · ·	
16.2	2 Materials and products for vacuum drainage systems	175
16.3	3 System design	175
	16.3.1 General	175
	16.3.2 Design requirements	176
	16.3.3 Vacuum recovery	177
	16.3.4 Vacuum pipework	177
	16.3.5 Vacuum pipe sizing	177
	16.3.6 Location of vacuum pipes	178
	16.3.7 Eccentric tapered fittings	179
	16.3.8 Change in pipe size	
	16.3.9 Grades of vacuum pipes	
16.4		
	16.4.1 Location and installation requirements	
	16.4.2 Size	
	16.4.3 Access to inspection openings	
	16.4.4 Sealing	
16.5		
16.6		
16.7		
16.8		
20.0	16.8.1 General	
	16.8.2 Sizing	
16.9		
10.	16.9.1 General	
	16.9.2 Vacuum soil fixture backflow prevention	
16.2	•	
10	16.10.1 Vacuum soil fixture lift pipe	
	16.10.2 Vacuum lift pipe connected to vacuum automatic interface unit	
	16.10.3 Vacuum lift pipe connection to horizontal vacuum pipe	
	16.10.4 Two-stage lift pipe	
16.1	9	
10.	11 Vacuum reforming pocket	TOO

	16.11.1 General	186
	16.11.2 Open type vacuum reforming pocket	187
	16.11.3 Closed type vacuum reforming pocket	187
16.12	Vacuum branch connections	
16.13	Vacuum pipes installed above ground	189
	16.13.1 General	189
	16.13.2 Bracketing and supports	189
	16.13.3 Brackets and supports	190
	16.13.4 Securing of pipes and fittings	190
16.14	Vacuum pipes installed below ground	190
	16.14.1 General	
	16.14.2 Anchor blocks	190
16.15	Vacuum test for vacuum drainage systems	190
	16.15.1 Sealing inlets	190
	16.15.2 Vacuum test pressure	190
	16.15.3 Maximum vacuum drop	191
Appendix A ((informative) Demonstrating products and materials are fit for purpose	192
Appendix B (normative) Maximum length of fixture discharge pipe without venting	194
Appendix C (informative) Pipe grades conversion	203
Appendix D ((informative) Conduct of inspections using closed circuit television	204
Appendix E (normative) Sizing vacuum drainage pipes and buffers	205
Appendix F (normative) Renovation of sanitary plumbing and drainage systems using	205
	structural plastics liners	207
Appendix G ((informative) Drains in unstable soils	210
Bibliography	<i>T</i>	216

Australian/New Zealand Standard

Plumbing and drainage

Part 2: Sanitary plumbing and drainage

Section 1 Scope and general

1.1 Scope

This document specifies requirements for the design and installation of sanitary plumbing and drainage from fixtures to a sewer, common effluent system or an on-site wastewater management system, as appropriate. It applies to new installations as well as alterations, additions or repairs to existing installations.

Illustrations used in this document are diagrammatic only and have been chosen without prejudice.

NOTE 1 The pre-treatment of trade wastes is not specified in this document.

NOTE 2 All sanitary plumbing and sanitary drainage installations for relocatable dwellings on long-term sites should conform to this document.

1.2 Application

1.2.1 Australia

This document shall be read in conjunction with the National Construction Code (NCC), Volume Three, the Plumbing Code of Australia (PCA).

Where alternative Australian or New Zealand Standards are referenced (e.g. AS 1345) the Australian Standard shall be used for Australia.

1.2.2 New Zealand

This document shall be read in conjunction with the New Zealand Building Code. This document may be used to demonstrate compliance with the New Zealand Building Code, Clause G13 Foul Water.

Where alternative New Zealand Standards are referenced (e.g. NZS 5807), the New Zealand Standard shall be used for New Zealand.

1.3 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document.

NOTE Documents referenced for informative purposes are listed in the Bibliography.

AS 1345, Identification of the contents of pipes, conduits and ducts

AS 4809, Copper pipe and fittings — Installation and commissioning

AS/NZS 1546.1, On-site domestic wastewater treatment units, Part 1: Septic tanks

AS/NZS 1546.2, On-site domestic wastewater treatment units, Part 2: Waterless composting toilets

AS 1546.3, On-site domestic wastewater treatment units, Part 3: Aerated wastewater treatment systems

AS/NZS 2032, Installation of PVC pipe systems

AS/NZS 2033, Installation of polyethylene pipe systems